© 2018. This manuscript version is made available under the CC-BY-NC-ND 4.0 license http://creativecommons.org/licenses/by-nc-nd/4.0/

Temporal downscaling of test reference years: effects on the long-term evaluation of photovoltaic systems

3

Ignacio García^{a*} and José Luis Torres^a

4 ^a Department of Projects and Rural Engineering, Public University of Navarre, Los Olivos Building,

5 Campus Arrosadía, 31006 Pamplona, Spain.

6 * Corresponding author: Tel.: +34 948 168405, Fax: +34 948 169148, email: <u>ignacio.garcia@unavarra.es</u>

7 ABSTRACT

8 Representative meteorological data from a given location are necessary to assess the longterm performance of photovoltaic (PV) systems. Test reference years (TRYs) or typical 9 10 meteorological years (TMYs) are widely used as input to PV models. Most of current 11 procedures propose the construction of TRYs by concatenating 12 months belonging to 12 different years of a dataset. This paper evaluates the effects of the temporal downscaling 13 of typical periods that compose different TRYs on the long-term assessment of PV 14 systems. The Festa-Ratto TRY, WYSS, EN ISO 15927-4 TRY, TMY3, TGY and TDY 15 are used. Thus, an adapted version of these six methodologies aimed at the selection of 16 typical days rather than months is proposed. The electricity production obtained by 17 simulation for daily and monthly TRYs is compared with simulations performed for each 18 actual year of the dataset. This analysis is performed for seven locations in the USA considering a 5.6 kWp grid-connected PV system. The results reveal that the timescale 19 20 reduction improves the behavior of Festa-Ratto TRY, WYSS, TMY3, TDY and TDY 21 when estimating the long-term production of a PV system considering the hourly, daily, 22 monthly and annual timescales, while the modified EN ISO 15927-4 TRY performs 23 worse than its monthly version.

24 KEYWORDS

25 test reference year; temporal downscaling; PV systems

26 NOMENCLATURE

27	EP_y	yearly electricity production of a year y (kWh).
28	EP_t	yearly electricity production of a reference year t (kWh).
29	j	number of years of the historic data series.
30	SEE _m	standard error of estimates on monthly electricity production of a month m .
31	EP_{ym}	monthly electricity production of a month m and a year y (kWh).
32	EP_{ymd}	daily electricity production of a day d of a month m of a year y (kWh).
33	\overline{EP}_m	mean value of monthly electricity production of a month m of long-term data (kWh).
34	EP_{tm}	monthly electricity production of a month m of a test reference year t (kWh).
35	$\sigma_{\overline{EP_m}}$	standard deviation of simple means of monthly electricity production of a month m (kWh).
36	SEE_d	standard error of estimates on daily electricity production of a day d .
37	EP_{yd}	daily electricity production of a day d of a year y (kWh).
38	EP_{td}	daily electricity production of a day d of a test reference year t (kWh).
39	\overline{EP}_{d}	mean value of daily electricity production of a day d of long-term data (kWh).
40	SEE_h	standard error of estimates on hourly electricity production of an hour h .
41	EP_{yh}	hourly electricity production of an hour h of a year y (kWh).
42	EP_{th}	hourly electricity production of an hour h of a test reference year t (kWh).
43	\overline{EP}_h	mean value of hourly electricity production of an hour h of long-term data (kWh).
44	$\Phi(p,d,i)$	long-term cumulative distribution function of the hourly means of a day d for a climatic
45		parameter <i>p</i> .
46	K(i)	rank order of the i^{th} hourly value of a parameter p for a day d .
47	Ν	total number of hours for a specific day over all the available years.
48	F(p,y,d,i)	short-term cumulative distribution function of the hourly means for a day d of a year y for a
49		climatic parameter <i>p</i> .
50	J(i)	rank order of the i^{th} value of the hourly means within a day d of a year y
51	n	number of hours for a specific day.
52	$F_{S}(p,y,d)$	Finkelstein-Schafer statistic of a day d within a year y for a climatic parameter p .
53	WS(y,d)	weighing sum of the F_S statistic of each parameter of a day d within a year y .
54	WF _x	weighing factor of parameter <i>x</i> .
55	Р	total number of parameters considered for the TMY3.

56 1. INTRODUCTION

57 Representative or typical meteorological data of the most frequent weather conditions at 58 a given location are frequently used to assess the long-term performance of photovoltaic 59 (PV) projects at the design stage. These datasets may be used for the simulation of 60 electrical energy supplied by a PV system over the long-term.

61 One of the first approaches that uses real measurements to characterize local climates 62 over the long term is the test reference year (TRY) of the National Climatic Data Center 63 [1], which consists of a selection of one whole year of meteorological measurements. 64 This method results in a particularly mild year as it progressively excludes years with 65 extreme weather conditions. As a result, most of the subsequent approaches propose the 66 construction of a TRY through the concatenation of 12 typical months belonging to 67 different years of a dataset. The dataset for this year thus includes 8,760 records 68 corresponding to the concatenation of hourly measurements for each selected month. The 69 meteorological data used for the generation of a TRY could come from both observed or 70 synthetic data. This issue is addressed by Lhendup and Lhundup [2] in a review of 71 different methodologies to generate TMY data when long-term observed meteorological 72 data is not available for a particular location.

73 One of the most commonly used approaches for the selection of a set of 12 typical 74 real months is the method developed by the Sandia National Laboratories (cited hereafter 75 as the Sandia method) [3], that leads to obtain the typical meteorological year (TMY). 76 Here, the Finkelstein-Schafer statistic (F_S) [4] is used to compare cumulative distribution 77 functions (CDFs) for both short- and long-term daily mean values of each meteorological 78 parameter considered. Then, for each month of the year, five candidate months are 79 selected according to the lower weighed sum (WS) of F_S values obtained for each 80 parameter. These five candidate months are ranked based on the closeness of a given month to the long-term mean and median. Finally, a persistence analysis is carried out to
select from the five candidates the typical meteorological month (TMM) that integrates
the TMY.

This method has been used by Pissimanis et al. [5] in the construction of a TMY for the city of Athens (Greece) and by Petrakis et al. [6] for its construction for Nicosia (Cyprus).

Sawaqed et al. [7] describe a step-by-step application of the Sandia method in
developing TMYs for seven locations in Oman while varying the weights proposed for
the original methodology. Ohunakin et al. [8] used this detailed description of the Sandia
method to obtain a TMY for Sokoto (Nigeria).

A subsequent modification of the Sandia National Laboratory methodology developed by the NREL that led the development of the TMY2 [9] maintains F_S statistic treatment although it modifies the considered climatic parameters and their weighing factors (*WF*). This method has been used by Kalogirou [10] in the generation of a TMY2 for Nicosia (Cyprus). In this way, modifications to the climatic variables and weighting coefficients proposed for the original Sandia method have been recommended by authors such as Chow et al. [11] and Zang et al. [12].

98 In 2002, the American Society of Heating, Refrigerating and Air-Conditioning 99 Engineers (ASHRAE) developed a procedure for obtaining the International Weather for 100 Energy Calculations (IWEC) [13]. This method follows the TMY procedure in terms of 101 selecting five candidate months, i.e., the five months with the lowest WS values. 102 However, the persistence criterion applied for the original Sandia method is omitted. 103 According to the authors, this criterion can lead to the rejection of all five candidate 104 months, particularly when data for only a few years are available. Instead, a typical month 105 is selected by choosing the candidate with the smallest deviation of monthly means and

106 medians from the long-term mean and median for dry-bulb temperature and solar 107 radiation.

108 Following from the IWEC philosophy, some proposals apply the Sandia procedure 109 regardless of the persistence criterion involved. In certain instances, the month with the 110 lowest WS of Finkelstein-Schafer statistics obtained for each meteorological variable is 111 integrated into the TMY. This was done by Chan et al. [14] in generating a TMY for 112 Hong Kong using 25 years of weather data. An updated Hong Kong TMY was recently 113 produced by Chan [15] on the basis of a 35-year measured weather dataset. Likewise, this 114 work presents a novel means of optimizing weights considered in the WS via the use of a 115 genetic algorithm. This procedure allows one to determine different sets of weighting 116 factors based on the energy system under evaluation. The Sandia modified procedure has 117 also been used for the generation of TMY datasets for 8 locations in Turkey representing 118 distinct climatic zones in the country [16] and for the construction of a TMY for 15 119 locations in the Argentine Littoral Region [17].

The elimination of all candidate months resulting from a strict application of the TMY procedure was addressed by Wilcox and Marion [18] in the development of the TMY3. Using this approach, the persistence criterion is relaxed to ensure that a candidate month is selected. Thus, when the TMY3 persistence procedure eliminates all candidate months, persistence is ignored and the candidate month with the closest mean and median to the long-term mean and median is selected.

The European technical standard EN ISO 15927-4 [19] describes another proposal based on the F_s statistic. It is aimed at the construction of a reference year suitable to evaluate the annual energy demand for heating and cooling in buildings. However, unlike the above-mentioned procedures, the EN ISO 15927-4 method (cited hereafter as the ISO method) assigns the same weight to all climatic variables considered. This method has been used by Kragh et al. [20] for the construction of two TRYs for Greenland. Likewise,
Kalamees and Kurnitski [21] used the ISO method for TRY generation for 6 locations in
Estonia and Lee et al. [22] used the method for TRY construction for 7 cities in South
Korea. Ruduks and Lešinskis [23] also generated an ISO TRY for Alūksne (Latvia) by
analyzing 30 years of weather data. In this case, due to unavailable solar radiation
measurements, the parameter was replaced with cloud coverage.

137 The ISO method proposes the use of dry bulb temperature, global horizontal radiation 138 and relative humidity as the main climatic variables. These three parameters are used to 139 select 3 candidate months. Then, wind speed is employed as a secondary parameter for 140 the selection of a typical month. Through the modified version proposed by Kalamees et 141 al. [24], only temperature and solar radiation are used as the main variables. This work 142 analyzed the influence of different climatic variables on a building's heating and cooling 143 energy consumption with the aim of developing weighting factors for the different 144 climatic variables. After observing that the air temperature has the strongest influence on 145 a building's energy consumption, a seasonally dependent weighting factor was developed 146 for this variable.

147 The behavior of the ISO TRY in evaluating the energy performance of buildings was 148 assessed by Pernigotto et al. [25] in reference to five cities in northern Italy. Along the 149 same line of research, Pernigotto et al. [26] developed two variations of the original ISO 150 method to improve its representativeness for building energy simulation.

151 The ISO method was also employed by Eames et al. [27] to replace the UK's TRY 152 released in 2006 [28]. Here, a modification was included so that once 3 candidate months 153 are selected according to the original procedure, the one with the lowest F_S statistic for 154 wind speed is chosen as the representative month.

155 While ISO TRY is specifically designed for the evaluation of buildings' thermal 156 energy demand, the suitability of this reference year when assessing the long-term 157 performance of PV systems was proved by García and Torres [29]. In this work, 158 electricity produced through a ISO TRY simulation was compared with that produced 159 from the Weather Year for Solar Systems (WYSS) [30]. Comparisons were performed 160 for seven locations in the USA in consideration of two 5.6 kWp grid-connected PV 161 systems. The WYSS is a system-oriented approach that only considers monthly energy 162 collected by the system as a selection parameter of typical months. Therefore, a 163 simulation process is involved when applying this method. In fact, this is one of the few 164 proposals that does not employ meteorological variables for the selection of typical 165 months that compose the TRY.

In line with the development of reference years focused on the evaluation of specific energy systems, the National Renewable Energy Laboratory (NREL) recently developed the typical global year (TGY) and typical direct year (TDY) [31]. These TRYs are suitable for the evaluation of photovoltaics and concentrating solar power projects. These reference years are the result of an application of TMY3 except that in this case, weighting is focused on irradiance rather than on meteorological data.

172 Between the different energy systems studied in the exhaustive work of Argiriou et 173 al. [32], a PV array of 5.8 m² facing south with a tilt angle of 40° was considered. Here, 174 a comparison of different methodologies to TRY generation was performed for the city 175 of Athens (Greece). Regarding the aforementioned PV system, of the 17 TRYs produced, 176 the three best were the Danish method [33,34], the modified Festa-Ratto method [35] and 177 one of the nine TMYs that only differs in terms of weights assigned to weather variables. 178 Despite the widespread use of the F_S statistic for comparing short- and long-term 179 cumulative distribution functions of variables involved, the Danish method and its

180 modification listed in the Festa-Ratto proposal use the Kolmogorov-Smirnov D-statistic181 (*KS*) [36].

A subsequent evaluation of TRYs involving comparisons of the long-term performance of different solar systems (thermal, passive and PV) was conducted by Bilbao et al. [37] in reference to two cities in Spain. With regard to the PV system considered, this work shows that the methods generating better results for PV systems were the Festa-Ratto modified for Madrid and the Danish method for Valladolid.

187 All of the procedures described thus far for the generation of test reference years 188 propose the selection of a set of twelve typical months composing the TRY. Nevertheless, 189 it seems reasonable to assume that a reduction in the timescale of selected typical periods could produce a more accurate assessment of the long-term behavior of PV systems. A 190 191 typical meteorological day (TMD) approach to predicting the performance of solar energy 192 systems was developed in the mid-1980s [38]. However, this methodology provides for 193 the selection of a single day of a time series that characterizes the long-term behavior of 194 a given system. Apart from this basic proposal, no existing studies present the 195 composition of a TRY from a concatenation of 365 typical real days of a dataset.

196 Against this backdrop, this work pursues a dual objective. First, the effects of the 197 temporal downscaling of typical periods that compose six different TRYs on the long-198 term assessment of PV systems are evaluated. Specifically, the Festa-Ratto TRY, WYSS, 199 ISO TRY, TMY3, TGY and TDY are used. To this end, an adapted version of these six 200 methodologies aimed at the selection of typical days rather than typical months is 201 proposed. Second, the performance of the TRYs based on meteorological variables is 202 compared with that of TRYs derived from an analysis of the electrical output of the PV 203 system.

204 2. METEOROLOGICAL DATA

The meteorological data used in this work were provided by the Surface Radiation Budget Network (SURFRAD). As shown in Fig. 1, the network includes a total of seven stations covering climatologically diverse regions across the USA. Basic geographic data for each station are shown in Table 1.

Table 1. Geographic data of the SURFRAD network stations.

Station	Code	Latitude (N)	Longitude (W)	Elevation (m)
Bondville, Illinois	BON	40° 3' 6"	88° 22' 24"	230
Table Mountain, Boulder, Colorado	TBL	40° 7' 32"	105° 14' 16"	1689
Desert Rock, Nevada	DRA	36° 37' 14"	116° 1' 403"	1007
Fort Peck, Montana	FPK	48° 18' 29"	105° 6' 6"	634
Goodwin Creek, Mississippi	GWN	34° 15' 17"	89° 52' 22"	98
Penn. State Univ. Pennsylvania	PSU	40° 43' 13"	77° 55' 51"	376
Sioux Falls, South Dakota	SXF	43° 44' 4"	96° 37' 24"	473

Despite the fact that SURFRAD stations measure and register numerous meteorological variables, only five were used for this work, namely dry-bulb air temperature, relative humidity, wind speed, global horizontal irradiance and direct normal irradiance. Regarding the length of the time series, the first SURFRAD stations established began recording in 1994 and the last one established began recording in 2003, and thus, all of them have a series of more than ten years of measurements. In fact, some offer almost double this amount (see Table 2).

216 Meteorological data are quality controlled by SURFRAD following the procedure 217 recommended by the Baseline Surface Radiation Network (BSRN) [39]. Measurements 218 are organized into daily files and are reported every three minutes to 31 December 2008. 219 Since this date, daily files of one-minute data are provided. The results of our analysis of 220 missing data performed on each dataset corresponding to the different stations are 221 presented in Table 2. Each meteorological variable has been analyzed independently for 222 the determination of percentages shown in the table. Thus, if for a given moment a record 223 of any of the four variables considered is missing or does not pass quality control

specifications, the whole moment is not discarded. As is shown, data for most of the available years show few gaps. Years with over 10% of records missing have been removed from the dataset. Isolated gaps up to one day or erroneous data found for the remaining years have been filled by the simple linear interpolation method between previous and subsequent days without missing data proposed by Argiriou et al. [32].

Vaar	Station code												
i ear	BON	TBL	DRA	FPK	GWN	PSU	SXF						
1996	2.80	1.80	-	-	1.00	-	-						
1997	5.80	1.00	-	5.80	3.20	-	-						
1998	0.40	0.40	-	1.60	1.00	-	-						
1999	12.80	0.00	0.20	0.60	0.80	0.00	-						
2000	0.20	0.20	0.80	0.00	0.00	1.60	-						
2001	0.00	0.20	0.20	4.60	0.20	0.00	-						
2002	0.60	0.20	1.20	0.20	0.00	0.20	-						
2003	0.00	0.20	0.00	0.20	9.40	0.00	-						
2004	0.20	0.20	0.00	0.40	12.80	5.20	0.00						
2005	0.40	0.20	2.40	0.20	0.00	1.00	0.40						
2006	2.40	0.20	1.00	0.80	0.00	0.80	0.80						
2007	0.00	0.00	0.00	0.00	1.20	4.00	0.40						
2008	0.20	0.20	2.00	0.20	0.80	0.40	0.00						
2009	1.00	0.60	0.00	0.00	2.00	0.60	0.00						
2010	0.00	0.20	3.00	0.00	3.40	0.00	0.00						
2011	0.00	0.20	0.00	0.00	3.60	0.20	0.20						
2012	0.00	0.00	0.00	0.00	0.00	0.00	1.00						
2013	0.20	0.20	0.00	0.00	2.20	1.00	0.20						
2014	0.00	0.00	0.20	0.20	2.80	0.20	0.20						
Period considered	1996-2014	1996-2014	1999-2014	1997-2014	1996-2014	1999-2014	2004-2014						
Removed years	1999	-	-	-	2004	-	-						
Total years	18	19	16	18	18	16	11						

Table 2. Annual percentages of missing data and time series considered for each station.

229 **3. METHODOLOGY**

230 For this work, six different methodologies for the generation of TRYs were adapted and

evaluated:

Festa-Ratto method: the procedure proposed by Festa and Ratto [35] allows for the
 use of any variable (empirical meteorological data or results of calculations such as
 estimations of the performance of a certain solar energy system). We took advantage
 of the method's flexibility. On the one hand, it was studied the behavior of the Festa-

Ratto TRY obtained from meteorological variables. On the other hand, a similar
evaluation was performed for the Festa-Ratto TRY generated on the basis of
electrical outputs of a PV system.

239 2) WYSS method: this is a system-oriented approach, as the selection of the typical 240 months that compose the TRY is based on analysis of the solar gain of the system 241 and not directly on meteorological parameters. Thus, technical characteristics of the 242 system concerned are implicitly involved in the selection of typical months to obtain 243 a reference year that minimizes the error involved in estimating the amount of energy 244 generated [30]. Despite the fact that this method was originally developed to assess 245 the long-term performance of solar thermal systems, for this work, it was modified 246 for use in PV systems as proposed in [29].

3) **ISO method:** the methodology proposed in the standard EN ISO 15927-4 bases the
selection of typical months on the comparison of short- and long-term CDFs of the
different meteorological variables considered.

250 TMY3 method: the procedure described by Wilcox and Marion [18] for the 4) 251 generation of the TMY version 3 (TMY3) data sets, was created based on the 252 methodology developed by Sandia National Laboratories to create the original TMYs 253 from the 1952-1975 SOL-MET/ERSATZ data [3]. The Sandia method bases the 254 selection of the typical months in the analysis of nine climatic parameters. However, 255 for the second version of the TMY (TMY2) and TMY3, an index for direct normal 256 irradiation was added. Also, for the TMY3, the persistence criteria were relaxed to 257 ensure that a candidate month would be selected from data series with fewer years 258 than those used in the two previous versions.

5) TDY and TGY methods: the methods developed by the NREL for obtaining typical
direct (normal irradiance) year (TDY) and typical global (horizontal) year (TGY)

data sets follow the principles of the TMY3. The only difference between the TMY3
and TDY and TGY data sets is the *WF* used for generating the data sets. The TDY
data set is developed using 100% weighting for direct normal irradiance, whereas the
TGY data set uses 100% weighting for global horizontal irradiance.

265 The original formulation of the six methods outlined above proposes the selection of 266 twelve typical months from a historical series of observations that will integrate the TRY. 267 As noted above, this paper aims to evaluate the effects of reducing the timescale of typical 268 periods on the adequacy of these TRYs for assessing the performance of PV systems over 269 the long term. Hence, each of the six methods was adapted with the objective of selecting 270 typical days rather than typical months. As a result of such variation, the new TRYs 271 obtained will result from the concatenation of 365 typical days selected from the multi-272 year dataset. Codes given to each of the fourteen TRYs analyzed along with their 273 parameters and WFs are shown in Table 3. As can be seen, 10 meteorological parameters 274 and one production parameter have been considered, namely maximum, minimum and mean dry-bulb air temperature $(T_{max}, T_{min}, \overline{T})$ and relative humidity $(RH_{max}, RH_{min}, \overline{RH})$ 275 276), maximum and mean wind speed (W_{max} , \overline{W}), global horizontal irradiance (\overline{G}), direct normal irradiance (\overline{D}) and electricity production of the PV system (\overline{EP}) . Given that the 277 278 study was extended to seven stations, 98 TRYs were considered in total.

TDV	M (1 1	Typical				Parar	neters a	nd weig	ghing fa	ctors			
IKY	Method	period	T_{max}	T_{min}	\overline{T}	RH _{max}	<i>RH_{min}</i>	\overline{RH}	W_{max}	\overline{W}	\overline{G}	\overline{D}	\overline{EP}
TRY _{ISOm}	EN ISO	Month	-	-	1/3	-	-	1/3	-	*	1/3	-	-
TRY _{ISOd}	EN ISO	Day	-	-	1/3	-	-	1/3	-	*	1/3	-	-
TRY_{WYSSm}	WYSS	Month	-	-	-	-	-	-	-	-	-	-	1
TRY_{WYSSd}	WYSS	Day	-	-	-	-	-	-	-	-	-	-	1
TRY_{FRMm}	Festa-Ratto	Month	-	-	1/4	-	-	1/4	-	1/4	1/4	-	-
TRY_{FRMd}	Festa-Ratto	Day	-	-	1/4	-	-	1/4	-	1/4	1/4	-	-
$\mathrm{TRY}_{\mathrm{FRPm}}$	Festa-Ratto	Month	-	-	-	-	-	-	-	-	-	-	1
$\mathrm{TRY}_{\mathrm{FRPd}}$	Festa-Ratto	Day	-	-	-	-	-	-	-	-	-	-	1
$TRY_{TMY3m} \\$	TMY3	Month	1/20	1/20	2/20	1/20	1/20	2/20	1/20	1/20	5/20	5/20	-
$TRY_{TMY3d} \\$	TMY3	Day	1/20	1/20	2/20	1/20	1/20	2/20	1/20	1/20	5/20	5/20	-
$TRY_{TGYm} \\$	TGY	Month	-	-	-	-	-	-	-	-	1	-	-
TRY_{TGYd}	TGY	Day	-	-	-	-	-	-	-	-	1	-	-
$TRY_{TDYm} \\$	TDY	Month	-	-	-	-	-	-	-	-	-	1	-
TRY_{TDYd}	TDY	Day	-	-	-	-	-	-	-	-	-	1	-

 Table 3. Description of the TRYs and parameters considered.

* In the ISO method the mean wind speed is used as a secondary parameter for the selection of a typical month, so it does not have a specific weight.

279	To assess the suitability of each TRY for estimating the long-term performance of a
280	PV system, for each of the stations referenced, the general procedure set out in Fig. 2 and
281	described below was followed:
282	• For each meteorological parameter, calculate the hourly and daily means for each
283	year included in the time series.
284	• Generate TRYs based on meteorological variables:
285	• From hourly meteorological files, construct TRYs composed of typical days.
286	• From daily meteorological files, construct TRYs composed of typical months.
287	• Estimate the hourly and daily electrical energy generated by the PV system for
288	each year of the dataset via PVSOL software simulation.
289	• Generate TRYs based on analysis of PV system production:
290	• From hourly production files, construct TRYs composed of typical days.
291	• From daily electricity production files, construct TRYs composed of typical
292	months.

Estimate the hourly electrical energy production of each TRY via PVSOL
simulation.

- Compare electricity production results obtained for each TRY with simulations
 performed for each year of the dataset using eight statistical indicators depicted
 by Equations (1)-(8) and described below.
- Finally, for each TRY, calculate the weighted average of the eight statistical
 indicators and classify of the values obtained.

300 As is shown in Fig. 2, annual, monthly and daily electric production results obtained 301 are compared with the results of simulations carried out for each year of the dataset using 302 eight different metrics. Six of them (F_1 to F_6) are proposed in [30]. Indicator F_1 obtained 303 from Equation (1) is the root mean square difference of the yearly energy productions of 304 the system. Equations (2) and (5) are used to determine indicators F_2 and F_5 . These are 305 the total standard error of estimates of monthly and daily energy outputs, respectively. 306 Indicator F_3 is the chi square parameter of monthly solar production, and it can be 307 calculated from Equation (3). Indicators F_4 and F_6 , which are derived from Equations (4) 308 and (6), are the root mean squares of the mean energy production of the historic data 309 series minus TRY monthly and daily production, respectively.

310 Given the temporal downscaling step proposed in this paper for selecting typical 311 moments, besides these six parameters, two more indicators (F_7 and F_8) are included. 312 These two metrics are aimed at evaluating the fit between hourly production simulated 313 for each TRY and long-term production. Specifically, indicator F_7 , which is expressed in 314 Equation (7), is the total standard error of estimates of hourly energy outputs. Equation 315 (8) can be used to calculate indicator F_8 . Analogously to indicators F_4 and F_6 , it 316 corresponds to the root mean square of the mean hourly energy production of the historic 317 data series minus hourly TRY production levels.

• Yearly electric energy production:

$$F_{1} = \sqrt{\frac{\sum_{y=1}^{j} (EP_{y} - EP_{t})^{2}}{j}}$$
(1)

• Monthly electric energy production:

$$F_{2} = \frac{1}{12} \cdot \sum_{m=1}^{12} SEE_{m} = \frac{1}{12} \cdot \left\{ \sum_{m=1}^{12} \left[\frac{\sum_{y=1}^{j} \left(EP_{ym} - EP_{tm} \right)^{2}}{j} \right]^{1/2} \right\}$$
(2)

$$F_{3} = \chi^{2} = \sum_{m=1}^{12} \left(\frac{\overline{EP}_{m} - EP_{im}}{\sigma_{\overline{EP}_{m}}} \right)$$
(3)

$$F_{4} = \left[\frac{1}{12} \cdot \sum_{m=1}^{12} \left(\overline{EP}_{m} - EP_{tm}\right)^{2}\right]^{1/2}$$
(4)

• Daily electric energy production:

$$F_{5} = \frac{1}{365} \cdot \sum_{d=1}^{365} SEE_{d} = \frac{1}{365} \cdot \left\{ \sum_{d=1}^{365} \left[\frac{\sum_{y=1}^{j} \left(EP_{yd} - EP_{td} \right)^{2}}{j} \right]^{1/2} \right\}$$
(5)

$$F_{6} = \left[\frac{1}{365} \sum_{d=1}^{365} \left(\overline{EP}_{d} - EP_{td}\right)^{2}\right]^{1/2}$$
(6)

• Hourly electric energy production:

$$F_{7} = \frac{1}{8760} \cdot \sum_{h=1}^{8760} SEE_{h} = \frac{1}{8760} \cdot \left\{ \sum_{h=1}^{8760} \left[\frac{\sum_{y=1}^{j} (EP_{yh} - EP_{th})^{2}}{j} \right]^{1/2} \right\}$$
(7)

$$F_8 = \left[\frac{1}{8760} \cdot \sum_{h=1}^{8760} \left(\overline{EP}_h - EP_{th}\right)^2\right]^{1/2}$$
(8)

322 **3.1. The modified Festa-Ratto method**

Festa and Ratto [35] seek to increase the accuracy of variable standardization and to compare the frequency distribution of each month in the database with the long-term frequency distribution through the use of the *KS* D-statistic [36]. Likewise, the temporal correlation between daily values of the different variables is taken into account by considering products of standardized residuals of each variable on consecutive days.

In this work, an adapted version of the original Festa-Ratto method aimed at the selection of representative days rather than representative months is proposed. The modified procedure (see Fig. 3) is described below:

• For each ordinal hour of each ordinal day of the year, calculate the long-term average $\mu_x(d,h)$ together with the corresponding long-term standard deviation $\sigma_x(d,h)$ of each considered variable *x*.

• From Equation (9), calculate the standardized residuals of all hourly values of the database x(y,d,h) with respect to the long-term trend.

$$X(y,d,h) = \frac{x(y,d,h) - \mu_x(d,h)}{\sigma_x(d,h)}$$
(9)

For each hourly datum of variables considered in the database, calculate the
 product of standardized residuals with respect to the trend from Equation (10).

$$z(y,d,h) = X(y,d,h)X(y,d,h+1)$$
(10)

For each ordinal hour of each ordinal day of the year, calculate the long-term
 average μ_z(d,h) together with the corresponding long-term standard deviation
 σ_z(d,h) of each variable considered z.

• For each hourly value of the considered variables, calculate the standardized residuals of z(y,d,h) with respect to long-term trends from Equation (11).

$$Z(y,d,h) = \frac{z(y,d,h) - \mu_z(d,h)}{\sigma_z(d,h)}$$
(11)

343	٠	For each X and Z parameter, calculate the following short-term quantities: the
344		average, standard deviation and CDF of each individual day of the multi-year data
345		series and variable.
346	•	For each X and Z parameter, calculate the following long-term quantities: the
347		average, standard deviation and CDF of each ordinal day of the year and variable.
348	٠	For each day d of each year y , calculate the distances between the short- and long-
349		term daily averages $d_{av}(y,d)$ and standard deviations $d_{sd}(y,d)$ as well as the
350		Kolmogorov-Smirnov parameter $d_{ks}(y,d)$ based on each $X(y,d,h)$ and $Z(y,d,h)$
351		parameter.
352	٠	For each day d of each year y and variable, calculate the composite distance of the
353		X(y,d,h) and $Z(y,d,h)$ parameters according to Equation (12).
		$d(y,d) = (1 - \alpha - \beta)d_{ks}(y,d) + \alpha \cdot d_{av}(y,d) + \beta \cdot d_{sd}(y,d) $ (12)
354		where $\alpha = \beta = 0.1$ as suggested for the original methodology. Therefore, for each
355		day and for each variable, two distances are available: $d(y,d)$ relative to the
356		standardized residuals $X(y,d,h)$ and $d(y,d)$ relative to the standardized residuals

357 Z(y,d,h).

Assign to each day the worst (maximum) distance d_{max}(y,d) of the distances calculated for this individual day.

• Finally, for each ordinal day, designate the day d of the year y that presents the 361 lowest value of $d_{max}(y,d)$ among those assigned in the previous step as indicated

362 in Equation (13). This day is considered typical and is selected for the TRY.

$$d_{\min\max}(d) = \min\left\{ d_{\max}(y,d) \left| 1 \le y \le j \right. \right\}$$
(13)

363 **3.2. The modified WYSS method**

The WYSS procedure is aimed at the determination of a set of typical weather data 364 365 suitable for the evaluation of the long-term performance of solar hot water systems 366 (SHWS). In doing so, the only parameter considered is the energy gain of a solar thermal 367 system. Nevertheless, the adapted version of the original method proposed and applied in 368 [29] for the long-term evaluation of PV systems, was used in this work. This implies that 369 the first stage of WYSS generation involves the simulation of the electrical production of 370 each year of a dataset. According to the original method, the selection of typical months 371 involves the minimization of errors in PV system monthly solar gain prediction. Thus, a 372 total of twelve typical months are selected from the dataset.

The modification of the original method performed in this work for selecting typical
days involves determining the daily output of the PV system for each year of the series.
The modified WYSS method described below is illustrated in Fig. 4:

Calculate the long-term daily mean value of electric production from Equation
(14).

$$\overline{EP}_{d} = \frac{\left(\sum_{y=1}^{j} EP_{yd}\right)}{j}$$
(14)

From Equation (15), calculate the squared difference between the daily electricity
production of day *d* of year *y* and the mean value of the daily energy output of the
same day from the long-term data.

$$\tau_{yd} = \left(EP_{yd} - \overline{EP}_d \right)^2 \tag{15}$$

• Select the day *d* of the year *y* with the lowest value of τ_{yd} . This day is considered 382 typical and is selected for the WYSS.

383 **3.3. The modified EN ISO 15927-4 method**

The standard EN ISO 15927-4 [19] describes a method for constructing a reference year suitable for evaluating the annual heating and cooling long-term energy needs of buildings. The procedure is designed to build a year of hourly meteorological data in which the mean value of individual variables, the cumulative distribution function and correlations between different variables of each month are as similar as possible to the values for the corresponding calendar month of the historical series.

The modified version of the original method proposed in this paper aims to reduce typical periods from months to days. As recommended through the procedure, the dry bulb temperature, global horizontal solar radiation and relative humidity are considered as the main selectors of days that make up the reference year with the wind speed used as a secondary selection parameter. This new approach, which is illustrated in Fig. 5, involves employing the following for each climatic parameter p, where p is the dry bulb temperature, global horizontal irradiance and relative humidity:

For each ordinal day, the long-term cumulative distribution function of hourly
 values for all years of the dataset is calculated for each parameter by sorting all
 hourly values in increasing order and by then using Equation (16).

$$\Phi(p,d,i) = \frac{K(i)}{N+1} \tag{16}$$

For each year of the dataset, the short-term cumulative distribution function of
 hourly values for each ordinal day is calculated by sorting all hourly values for
 that day and year in increasing order and then using Equation (17).

$$F(p, y, d, i) = \frac{J(i)}{n+1} \tag{17}$$

403 • 404 For each ordinal day, the F_S statistic is calculated for each year of the dataset using Equation (18).

$$F_{s}(p, y, d) = \sum_{i=1}^{n} \left| F(p, y, d, i) - \Phi(p, d, i) \right|$$
(18)

• For each ordinal day, individual days are ranked from the multiyear record in order of increasing F_s statistic for each parameter. Then, the individual ranks of the three climate parameters are summed to determine the total ranking.

For each ordinal day, for the three days with the lowest ranking, the deviation of
 the daily mean wind speed from the corresponding multi-year ordinal day is
 calculated. The day with the lowest deviation in wind speed is selected as the best
 day to include in the reference year.

Finally, the original method involves the use of a cubic spline for smoothing the transitioning of climatic variables from each selected month to the next. Given that this adjustment refers to hours in which solar radiation is zero or very low, this aspect was not taken into consideration in this work.

416 During the last step of this process, some coincidences in the sum of rank orders of 417 the F_S statistic of the three main variables can occur. Therefore, in certain cases, it is not 418 possible to select the three months or days with the lowest ranking. In an attempt to 419 address this problem, García and Torres [29] proposed the use of a secondary selection 420 criterion whereby when there is a tie in the total ranking, priority is given to months or 421 days with the lowest individual order of F_S in the radiation variable. This particular 422 selection condition, which is illustrated in Fig. 5 as a dashed line, was used in the present 423 study.

424 **3.4. The modified TMY3 method**

The TMY3 procedure is an empirical approach based on the Sandia method that selects individual months from different years occurring in the period of record. As was done for the previous methods, an adapted version of the original TMY3 method aimed at the 428 selection of representative days is proposed (see Fig. 6). The modified procedure is429 described below:

• For each ordinal day, 5 candidate days are selected having the smallest WS of the 431 F_S statistic (Equation (18)) of each of the 10 hourly parameters, calculated 432 according to Equation (19).

$$WS(y,d) = \sum_{x=1}^{P} WF_x \cdot F_{S,x}(y,d)$$
(19)

The 5 candidate days are ranked with respect to closeness of the day to the longterm mean and median. Relative differences are calculated between the mean and
median air temperature and global horizontal irradiance of each specific day and
the respective mean and medians over the long term. The maximum of the four
relative differences is assigned.

- The persistence of hourly dry bulb temperature and global horizontal irradiance
 are evaluated by determining the frequency and run length above and below fixed
 long-term percentiles. For hourly dry bulb temperature, the frequency and run
 length above the 67th percentile (consecutive warm hours) and below the 33rd
 percentile (consecutive cool hours) are determined. For global horizontal
 irradiance, the frequency and run length below the 33rd percentile (consecutive
 low radiation hours) are determined.
- The persistence data are used to select, from the five candidate days, the day to be used in the TMY3. The highest ranked candidate day from the previous step that meets the persistence criteria is used in the TMY3. The persistence criteria exclude the day with the longest run, the day with the most runs, and the day with zero runs. However, a candidate day is only excluded if it has more runs than every other candidate day. So, if two candidate days tie for the most runs, neither is eliminated by the TMY3 procedure. Also, if the TMY3 persistence procedure

452 eliminated all candidate days, persistence is ignored and the closest day to the453 long-term mean and median is selected.

454 Applying a cubic spline to flatten the variable transition from a month to the next is 455 recommended in the original procedure. However, for the reasons already stated, it has 456 not been applied in this work.

457 Along with the TMY3 method, the original procedures for obtaining TDY and TGY 458 data sets have been modified for the selection of typical days instead of months. To obtain 459 the daily versions of TDY and TGY, the modified procedure described above for TMY3 460 is applicable with the difference that only the direct normal irradiance is used for TDY 461 generation and global horizontal irradiance for TGY. Therefore, in both cases, the ranking 462 of the five candidate days according to the relative distance in mean and median as well 463 as the determination of the frequency and run length below the 33rd percentile is restricted 464 to the only variable used.

465 4. RESULTS AND DISCUSSION

466 4.1. TRY generation

467 First, following the procedures described in Section 3, TRYs based on meteorological
468 variables were generated, namely, both daily and monthly TRY_{FRM}, TRY_{ISO}, TRY_{TMY3},
469 TRY_{TDY} and TRY_{TGY}.

470 Meanwhile, the generation of production-based TRYs (TRY_{FRP} and TRY_{WYSS}) 471 involves a previous simulation of electrical energy generated from the PV system for each 472 year of the time series and for each location. For this, as is explained above, PVSOL 473 simulation software was used. The input weather file used in the program consisted of a 474 list of 8,760 hourly values of dry bulb temperature, global horizontal irradiance, relative 475 humidity and wind speed. Diffuse and direct components of global irradiance are 476 determined by PVSOL through the correlation proposed by Reindl with reduced 477 coefficients [40] and the anisotropic model developed by Hay and Davis [41] is used by478 the software to estimate the diffuse irradiance on the tilted surface.

The behavior of the different TRYs was evaluated by comparing electrical outputs provided through a grid-connected 5.60 kWp PV system (see Table 4). As shown in the last row of the Table 4, the tilt angle of the collector surface was set up at each location according to the maximum interception of solar energy for the entire measurement period.

Table 4. Technical data of the PV system.

PV power (kWp)	5.60
Number of PV modules	56
Number of PV modules in series	14
Number of PV modules in parallel	4
Solar tracking system	No
System azimuth angle (°S)	0
System tilt angle (°)	Local optimum (long-term)

Given the length of the different series of observations, 116 executions of the simulation software were performed. The electricity production results obtained were used for the construction of monthly and daily TRY_{WYSS} and TRY_{FRP} , and to assess the adequacy of each TRY in estimating the long-term behavior of the PV system. This analysis is presented in Section 4.2.

488 After selecting typical days or months that make up the different reference years, each 489 TRY was built to create a set of 8,760 values corresponding to the four meteorological 490 variables considered. In using PVSOL again, the energy output of the PV system provided 491 for each reference year was simulated.

492 **4.2. TRY evaluation**

As described in Section 3, the last step of the general procedure involves the
determination of the eight statistical indicators (Equations (1)-(8)) suitable for assessing
the adequacy of different TRYs at estimating the long-term energy produced by the PV
system.

497 The values of the eight metrics obtained for each TRY for the seven locations 498 considered are shown in Table 5-Table 12. To facilitate analysis of the results, each table 499 classifies TRYs by station. A score of '1' is assigned to the TRY with a lower value of 500 the corresponding indicator, and a value of '14' is assigned to that with the highest value. 501 This implies an ordering of TRYs from best to worst while attending to the indicator and 502 station considered in each case. These rank orders are shown in brackets next to each 503 value. Furthermore, the sum of various orders reached by each TRY based on all stations 504 is shown in the last column. The fourteen different TRYs have been ordered from lowest 505 to highest value of orders' sum for each table.

506 Table 5 shows the results of the annual indicator F_1 for each location, i.e., the root 507 mean square difference of the yearly energy productions. TRY_{WYSSm} presents the lowest 508 deviation in estimating annual production levels for four of the seven stations analyzed. 509 This is followed closely by TRY_{WYSSd}, which takes the first position for two stations, 510 while TRY_{TDYm} shows the lowest deviation for the remaining station. However, TRY_{ISOm} 511 also achieves a better result than TRY_{TDYm} when all stations are considered. In fact, 512 TRY_{TDYm} ranks fourth followed by TRY_{TMY3m} and TRY_{TGYm}. The daily version of the 513 ISO reference year, the TRY_{ISOd}, generates F_1 values that are significantly higher than 514 those of any of the other TRYs.

TDV	Station Code														
IKI	BON		DRA		FPK		GWN		PSU		SXF		TBL		Totai
WYSSm	315.57	(1)	177.33	(1)	258.84	(2)	354.61	(1)	256.42	(4)	233.28	(1)	200.47	(3)	(13)
WYSSd	322.24	(5)	186.10	(4)	258.83	(1)	357.94	(4)	252.05	(2)	239.91	(3)	200.31	(1)	(20)
ISOm	319.60	(4)	206.49	(7)	294.16	(3)	355.89	(3)	266.94	(7)	233.67	(2)	211.34	(5)	(31)
TDYm	340.10	(7)	183.23	(3)	317.02	(5)	360.94	(5)	251.86	(1)	308.08	(7)	391.75	(9)	(37)
TMY3m	317.01	(3)	178.93	(2)	319.91	(6)	392.27	(8)	270.68	(8)	429.85	(11)	247.92	(7)	(45)
TGYm	326.91	(6)	186.96	(5)	321.19	(7)	371.08	(6)	277.74	(10)	284.95	(5)	303.50	(8)	(47)
FRPd	391.07	(10)	188.07	(6)	315.27	(4)	372.17	(7)	283.37	(11)	349.28	(8)	202.69	(4)	(50)
TGYd	316.63	(2)	727.03	(13)	529.93	(12)	354.76	(2)	259.85	(5)	380.87	(10)	590.98	(13)	(57)
FRMm	425.66	(12)	345.16	(8)	404.74	(8)	414.20	(9)	506.21	(13)	286.28	(6)	200.44	(2)	(58)
TMY3d	370.97	(8)	496.87	(9)	432.56	(9)	416.08	(10)	287.72	(12)	262.52	(4)	440.67	(10)	(62)
FRPm	377.16	(9)	501.34	(10)	491.08	(11)	754.73	(13)	271.99	(9)	675.48	(12)	216.50	(6)	(70)
TDYd	441.97	(13)	660.38	(12)	490.39	(10)	436.39	(11)	260.98	(6)	362.77	(9)	513.94	(11)	(72)
FRMd	393.02	(11)	598.80	(11)	552.68	(13)	604.79	(12)	252.48	(3)	987.90	(13)	582.23	(12)	(75)
ISOd	1253.60	(14)	927.60	(14)	1429.31	(14)	1506.60	(14)	1131.04	(14)	1298.79	(14)	1288.19	(14)	(98)

Table 5. Values of F_I indicator (root mean square difference of the yearly energy productions in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

515	The results concerning monthly indicators F_2 (total standard error of estimates of
516	monthly energy outputs), F_3 (chi square parameter of monthly solar production) and F_4
517	(root mean square of the mean energy production of the historic data series minus TRY
518	monthly production) are presented in Table 6-Table 8. In this case, we find that for almost
519	all the locations, TRY_{WYSSm} works best, followed by TRY_{WYSSd} . A unique exception is
520	found for Fort Peck, for which this latter reference year occupies first place of the F_2 and
521	F_4 rankings. Nevertheless, in both cases, we found a minimal difference between values
522	obtained for the daily and monthly TRY $_{WYSS}$. Meanwhile, TRY $_{TGYm}$ and TRY $_{FRPd}$ occupy
523	the fourth and fifth positions respectively for the three indicators. The worst results are
524	obtained from TRY _{ISOd} , TRY _{FRMm} and TRY _{FRPm} .

TDV							Station	Code							Total
IKI	BON		DRA		FPK		GWN		PSU		SXF		TBL		Total
WYSSm	62.97	(1)	46.59	(1)	64.61	(2)	70.38	(1)	63.78	(1)	63.74	(1)	48.63	(1)	(8)
WYSSd	63.51	(2)	46.80	(2)	64.61	(1)	70.67	(2)	63.99	(2)	64.18	(2)	48.68	(2)	(13)
TGYm	64.00	(3)	48.84	(3)	67.92	(4)	72.61	(3)	66.24	(3)	67.20	(3)	53.52	(5)	(24)
FRPd	71.24	(7)	50.69	(6)	67.49	(3)	73.02	(4)	66.55	(4)	76.92	(10)	50.40	(3)	(37)
ISOm	67.73	(6)	49.09	(4)	68.03	(5)	75.11	(6)	72.56	(9)	73.73	(7)	52.76	(4)	(41)
TDYm	67.58	(5)	51.87	(7)	77.08	(7)	75.35	(7)	67.39	(5)	71.96	(4)	58.36	(7)	(42)
TMY3m	66.53	(4)	50.54	(5)	81.40	(10)	74.46	(5)	67.92	(7)	74.99	(9)	53.99	(6)	(46)
TMY3d	72.90	(9)	62.08	(8)	84.84	(11)	80.76	(8)	67.86	(6)	74.64	(8)	60.62	(8)	(58)
TDYd	79.57	(11)	70.84	(11)	77.54	(8)	84.35	(10)	73.02	(10)	72.42	(5)	63.26	(9)	(64)
TGYd	74.44	(10)	75.51	(12)	76.89	(6)	86.55	(11)	75.85	(11)	73.57	(6)	67.45	(10)	(66)
FRMd	72.06	(8)	67.89	(9)	79.15	(9)	83.88	(9)	69.06	(8)	105.05	(12)	69.80	(11)	(66)
FRMm	86.17	(12)	69.73	(10)	94.40	(12)	138.60	(12)	97.82	(12)	101.69	(11)	73.29	(12)	(81)
FRPm	109.09	(13)	96.50	(14)	118.11	(13)	160.75	(14)	117.42	(14)	121.60	(13)	90.78	(13)	(94)
ISOd	123.15	(14)	89.78	(13)	134.52	(14)	141.44	(13)	113.39	(13)	125.42	(14)	116.85	(14)	(95)

Table 6. Values of the F_2 indicator (total standard error of estimates of monthly energy outputs in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

Table 7. Values of the F_3 indicator (chi square parameter of monthly solar production) for each TRY and station (the ranked order of each value is shown in brackets).

TDV							Station	Code							Total
IKI	BON		DRA		FPK		GWN		PSU		SXF		TBL		Totai
WYSSm	0.08	(1)	0.07	(1)	0.08	(1)	0.06	(1)	0.08	(1)	0.14	(1)	0.08	(1)	(7)
WYSSd	0.27	(2)	0.22	(2)	0.10	(2)	0.17	(2)	0.17	(2)	0.28	(2)	0.11	(2)	(14)
TGYm	0.55	(3)	1.20	(3)	1.27	(3)	0.93	(3)	1.29	(3)	1.63	(3)	2.88	(5)	(23)
FRPd	3.36	(7)	2.93	(6)	1.48	(4)	1.20	(4)	1.32	(4)	5.74	(7)	1.40	(3)	(35)
TDYm	2.03	(5)	3.46	(7)	4.83	(6)	1.94	(6)	1.71	(6)	3.43	(4)	5.98	(7)	(41)
ISOm	2.23	(6)	1.46	(4)	1.55	(5)	1.98	(7)	3.72	(9)	5.23	(6)	2.39	(4)	(41)
TMY3m	1.45	(4)	2.60	(5)	8.13	(10)	1.79	(5)	2.20	(7)	4.68	(5)	2.92	(6)	(42)
TMY3d	4.19	(9)	12.03	(8)	11.91	(11)	5.03	(8)	1.68	(5)	7.30	(10)	6.80	(8)	(59)
FRMd	4.02	(8)	15.44	(9)	6.32	(7)	5.15	(9)	2.23	(8)	24.11	(12)	14.67	(11)	(64)
TDYd	8.69	(11)	16.88	(11)	7.70	(9)	6.39	(10)	4.57	(10)	6.02	(8)	8.10	(9)	(68)
TGYd	5.83	(10)	22.13	(12)	7.22	(8)	7.84	(11)	6.99	(11)	6.39	(9)	10.73	(10)	(71)
FRMm	13.05	(12)	16.53	(10)	16.84	(12)	38.01	(13)	22.75	(12)	20.31	(11)	17.92	(12)	(82)
ISOd	44.19	(14)	36.60	(13)	45.28	(14)	36.54	(12)	29.05	(13)	44.69	(14)	55.55	(14)	(94)
FRPm	26.18	(13)	45.48	(14)	29.91	(13)	49.07	(14)	33.95	(14)	30.39	(13)	33.02	(13)	(94)

TDV							Station	Code							Total
IKY	BON		DRA		FPK		GWN		PSU		SXF		TBL		Total
WYSSm	4.54	(1)	4.53	(1)	5.51	(2)	4.18	(1)	5.44	(1)	7.04	(1)	4.30	(1)	(8)
WYSSd	9.57	(2)	5.77	(2)	4.98	(1)	7.37	(2)	7.36	(2)	10.53	(2)	4.63	(2)	(13)
TGYm	11.62	(3)	16.34	(3)	22.85	(5)	18.25	(3)	18.01	(3)	23.48	(3)	23.17	(5)	(25)
FRPd	35.27	(7)	19.98	(5)	19.45	(3)	18.50	(4)	19.22	(4)	45.60	(10)	12.65	(3)	(36)
ISOm	25.71	(6)	16.73	(4)	21.76	(4)	25.77	(6)	37.24	(10)	38.85	(7)	20.72	(4)	(41)
TMY3m	22.98	(4)	21.99	(6)	50.71	(9)	23.66	(5)	22.57	(6)	43.76	(9)	24.23	(6)	(45)
TDYm	25.03	(5)	23.08	(7)	51.34	(10)	28.58	(7)	22.20	(5)	37.58	(6)	34.92	(7)	(47)
TMY3d	38.21	(9)	40.80	(8)	54.72	(11)	39.50	(8)	24.42	(7)	40.28	(8)	38.79	(8)	(59)
TDYd	48.68	(11)	54.60	(10)	42.58	(7)	46.66	(9)	35.66	(9)	33.83	(4)	42.31	(9)	(59)
TGYd	39.81	(10)	60.03	(12)	41.29	(6)	50.06	(11)	40.46	(11)	37.39	(5)	48.29	(10)	(65)
FRMd	37.18	(8)	51.10	(9)	48.27	(8)	48.96	(10)	27.59	(8)	89.33	(12)	55.10	(11)	(66)
FRMm	65.80	(12)	59.54	(11)	79.19	(12)	133.29	(13)	81.79	(12)	88.27	(11)	59.48	(12)	(83)
ISOd	109.17	(14)	79.04	(13)	119.52	(14)	129.06	(12)	97.31	(13)	112.28	(14)	109.87	(14)	(94)
FRPm	98.84	(13)	87.62	(14)	111.55	(13)	181.84	(14)	104.03	(14)	109.70	(13)	79.32	(13)	(94)

Table 8. Values of the F_4 indicator (root mean square of the mean energy production of the historic data series minus TRY monthly production in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

527 Regarding the F_5 and F_6 indicators (total standard error of estimates of daily energy 528 outputs and root mean square of the mean energy production of the historic data series 529 minus TRY daily production respectively), the reference year that better predicts the daily 530 electricity production in the long term is TRY_{WYSSd} for all of the locations (see Table 9 531 and Table 10). With a slightly higher score, it is followed in descending order by 532 TRY_{TGYd}, TRY_{TDYd} and TRY_{FRPd}. That is, although the first position is occupied by a 533 TRY obtained by analyzing the electrical output of the PV system, TRYs based on the 534 analysis of only the global horizontal irradiance (TRY_{TGYd}) and direct normal irradiance 535 (TRY_{FRPd}) rank second and third in the overall rating. It can be seen that the seven TRYs 536 composed of typical days perform better in estimating daily energy production patterns 537 than their monthly versions. TRYs obtained from the original Festa-Ratto method 538 generate the worst overall results.

TRY	Station Code														Total
	BON		DRA		FPK		GWN		PSU		SXF		TBL		1 otal
WYSSd	9.24	(1)	5.25	(1)	8.07	(1)	8.77	(1)	9.22	(1)	8.99	(1)	7.73	(1)	(7)
TGYd	9.61	(2)	5.65	(2)	8.44	(2)	9.22	(2)	9.72	(2)	9.46	(2)	8.11	(3)	(15)
TDYd	9.93	(4)	5.67	(3)	8.80	(4)	9.41	(3)	9.95	(4)	9.71	(3)	8.30	(4)	(25)
FRPd	9.87	(3)	6.49	(7)	8.45	(3)	9.47	(4)	9.82	(3)	11.70	(7)	8.00	(2)	(29)
TMY3d	10.70	(5)	5.86	(4)	9.36	(5)	9.95	(5)	10.59	(5)	10.47	(5)	8.91	(5)	(34)
ISOd	10.73	(6)	6.02	(6)	9.60	(7)	10.40	(6)	10.80	(6)	10.43	(4)	9.04	(6)	(41)
FRMd	10.97	(7)	5.99	(5)	9.47	(6)	10.57	(7)	10.83	(7)	10.81	(6)	9.22	(7)	(45)
WYSSm	12.55	(10)	6.87	(11)	11.05	(13)	11.48	(8)	12.43	(9)	11.78	(9)	10.27	(9)	(69)
TMY3m	12.52	(9)	6.97	(12)	10.98	(12)	11.77	(9)	12.48	(12)	11.77	(8)	10.28	(10)	(72)
TDYm	12.45	(8)	6.85	(10)	10.96	(11)	11.89	(12)	12.46	(11)	11.99	(12)	10.07	(8)	(72)
ISOm	12.59	(11)	6.82	(8)	10.81	(9)	11.86	(11)	12.66	(13)	11.97	(10)	10.46	(12)	(74)
TGYm	12.67	(12)	6.84	(9)	10.75	(8)	11.78	(10)	12.45	(10)	12.09	(13)	10.52	(13)	(75)
FRMm	12.91	(14)	7.36	(13)	10.89	(10)	12.24	(13)	12.68	(14)	11.97	(11)	10.36	(11)	(86)
FRPm	12.85	(13)	7.57	(14)	11.48	(14)	12.75	(14)	12.42	(8)	12.59	(14)	10.55	(14)	(91)

Table 9. Values of the F_5 indicator (total standard error of estimates of daily energy outputs in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

539

Table 10. Values of the F_6 indicator (root mean square of the mean energy production of the historic data series minus TRY daily production in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

TRY	Station Code														T-4-1
	BON		DRA		FPK		GWN		PSU		SXF		TBL		Total
WYSSd	1.46	(1)	0.87	(1)	1.04	(1)	1.33	(1)	1.37	(1)	1.98	(1)	0.89	(1)	(7)
TGYd	3.05	(2)	2.36	(2)	2.71	(2)	3.32	(2)	3.47	(2)	3.68	(2)	2.68	(3)	(15)
TDYd	4.07	(4)	2.46	(3)	3.79	(4)	3.90	(3)	4.10	(4)	4.39	(3)	3.33	(4)	(25)
FRPd	3.95	(3)	4.67	(7)	2.81	(3)	4.15	(4)	3.82	(3)	8.46	(7)	2.32	(2)	(29)
TMY3d	6.00	(6)	3.11	(4)	5.10	(5)	5.39	(5)	5.72	(5)	6.18	(5)	4.85	(5)	(35)
ISOd	5.96	(5)	3.42	(6)	5.57	(7)	6.27	(6)	6.24	(7)	6.03	(4)	5.02	(6)	(41)
FRMd	6.40	(7)	3.30	(5)	5.33	(6)	6.50	(7)	6.19	(6)	6.77	(6)	5.43	(7)	(44)
WYSSm	9.24	(10)	5.61	(9)	8.40	(13)	8.29	(8)	9.12	(11)	8.58	(9)	7.49	(9)	(69)
TDYm	9.07	(8)	5.68	(11)	8.12	(10)	8.92	(11)	9.11	(10)	8.92	(12)	7.09	(8)	(70)
TMY3m	9.20	(9)	5.75	(12)	8.35	(12)	8.68	(9)	9.16	(12)	8.52	(8)	7.52	(10)	(72)
TGYm	9.45	(12)	5.62	(10)	7.87	(9)	8.73	(10)	9.10	(9)	9.01	(13)	7.98	(13)	(76)
ISOm	9.38	(11)	5.52	(8)	7.84	(8)	8.96	(12)	9.45	(14)	8.82	(11)	7.83	(12)	(76)
FRMm	9.84	(14)	6.70	(13)	8.13	(11)	9.54	(13)	9.40	(13)	8.78	(10)	7.71	(11)	(85)
FRPm	9.62	(13)	6.91	(14)	9.15	(14)	10.22	(14)	9.04	(8)	9.79	(14)	8.08	(14)	(91)

540 The results obtained after calculating the F_7 and F_8 indicators are presented in Table 541 11 and Table 12. It should be remembered that the F_7 indicator corresponds to the total

542 standard error of estimates of hourly energy outputs and while the F_8 indicator is the root

543 mean square of the mean hourly energy production of the historic data series minus hourly 544 TRY production. As is apparent from the tables, TRY_{WYSSd} performs best for five of the 545 seven locations studied. However, for Desert Rock and Table Mountain, this reference 546 year is surpassed by TRY_{TGYd}, which ranks second for the rest of the stations. TRY_{TDYd} 547 and TRY_{ISOd} are ranked third and fourth, respectively. As was found to be the case for 548 daily indicators, TRYs consisting of typical days show the slightest errors in the 549 estimation of hourly production in the long term. Of the seven reference years 550 compounded by typical months, those obtained from the Festa-Ratto method are the worst

551 in all cases.

Table 11. Values of the F_7 indicator (total standard error of estimates of hourly energy outputs in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

TRY	Station Code														T-4-1
	BON		DRA		FPK		GWN		PSU		SXF		TBL		I otal
WYSSd	0.511	(1)	0.313	(4)	0.485	(1)	0.483	(1)	0.529	(1)	0.505	(1)	0.511	(2)	(11)
TGYd	0.522	(2)	0.302	(1)	0.491	(2)	0.493	(2)	0.545	(2)	0.515	(2)	0.508	(1)	(12)
TDYd	0.530	(3)	0.310	(3)	0.503	(3)	0.499	(3)	0.549	(3)	0.523	(3)	0.517	(4)	(22)
ISOd	0.540	(4)	0.308	(2)	0.504	(4)	0.517	(5)	0.560	(5)	0.531	(4)	0.514	(3)	(27)
TMY3d	0.551	(5)	0.313	(5)	0.511	(5)	0.512	(4)	0.558	(4)	0.542	(5)	0.528	(5)	(33)
FRMd	0.560	(7)	0.317	(6)	0.515	(6)	0.534	(7)	0.570	(6)	0.549	(6)	0.534	(6)	(44)
FRPd	0.559	(6)	0.345	(7)	0.523	(7)	0.533	(6)	0.575	(7)	0.575	(9)	0.539	(7)	(49)
WYSSm	0.597	(8)	0.354	(11)	0.553	(12)	0.554	(8)	0.607	(9)	0.573	(8)	0.561	(10)	(66)
TMY3m	0.598	(9)	0.354	(12)	0.556	(13)	0.564	(9)	0.611	(12)	0.571	(7)	0.559	(9)	(71)
TDYm	0.599	(10)	0.352	(9)	0.549	(11)	0.572	(12)	0.610	(10)	0.580	(11)	0.550	(8)	(71)
ISOm	0.599	(11)	0.347	(8)	0.542	(8)	0.569	(11)	0.617	(14)	0.580	(10)	0.565	(13)	(75)
TGYm	0.604	(12)	0.352	(10)	0.545	(9)	0.566	(10)	0.611	(11)	0.585	(13)	0.564	(11)	(76)
FRMm	0.610	(14)	0.372	(13)	0.548	(10)	0.579	(13)	0.615	(13)	0.581	(12)	0.564	(12)	(87)
FRPm	0.606	(13)	0.380	(14)	0.570	(14)	0.593	(14)	0.607	(8)	0.603	(14)	0.568	(14)	(91)

TDV	Station Code													Total	
11/1	BON		DRA		FPK		GWN		PSU		SXF		TBL		Total
WYSSd	0.458	(1)	0.304	(4)	0.474	(1)	0.430	(1)	0.494	(1)	0.476	(1)	0.520	(2)	(11)
TGYd	0.502	(2)	0.261	(1)	0.494	(2)	0.468	(2)	0.548	(2)	0.510	(2)	0.514	(1)	(12)
TDYd	0.528	(3)	0.294	(2)	0.534	(3)	0.489	(3)	0.565	(3)	0.539	(3)	0.545	(4)	(21)
ISOd	0.561	(4)	0.294	(3)	0.541	(4)	0.556	(5)	0.604	(5)	0.566	(4)	0.532	(3)	(28)
TMY3d	0.597	(5)	0.319	(5)	0.564	(5)	0.540	(4)	0.595	(4)	0.601	(5)	0.585	(5)	(33)
FRMd	0.619	(7)	0.330	(6)	0.576	(6)	0.607	(7)	0.631	(6)	0.617	(6)	0.604	(6)	(44)
FRPd	0.611	(6)	0.444	(7)	0.590	(7)	0.596	(6)	0.636	(7)	0.698	(9)	0.608	(7)	(49)
WYSSm	0.727	(8)	0.479	(11)	0.688	(12)	0.669	(8)	0.735	(9)	0.697	(8)	0.682	(10)	(66)
TMY3m	0.730	(9)	0.488	(12)	0.701	(13)	0.691	(9)	0.745	(12)	0.692	(7)	0.675	(9)	(71)
TDYm	0.733	(10)	0.473	(9)	0.676	(10)	0.711	(12)	0.740	(11)	0.712	(11)	0.651	(8)	(71)
TGYm	0.746	(12)	0.477	(10)	0.662	(9)	0.699	(10)	0.739	(10)	0.723	(13)	0.688	(11)	(75)
ISOm	0.736	(11)	0.463	(8)	0.659	(8)	0.708	(11)	0.760	(14)	0.716	(12)	0.692	(13)	(77)
FRMm	0.765	(14)	0.549	(13)	0.681	(11)	0.738	(13)	0.751	(13)	0.709	(10)	0.690	(12)	(86)
FRPm	0.751	(13)	0.562	(14)	0.741	(14)	0.773	(14)	0.728	(8)	0.773	(14)	0.703	(14)	(91)

Table 12. Values of the F_8 indicator (root mean square of the mean hourly energy production of the historic data series minus hourly TRY production in kWh) for each TRY and station (the ranked order of each value is shown in brackets).

553 The F_G parameter defined in Equation (20) was used to evaluate the overall 554 performance of the TRYs. This is the weighted average of ranked orders obtained from 555 the eight statistical indicators calculated for each reference year. Under this weighting, 556 the same importance is given to the annual rank order, to the average of the three monthly 557 orders, to the average of the two daily orders and to the average of the two hourly orders. 558 The results obtained for the various combinations of TRYs and locations are presented in 559 Table 13. The last column of this table shows the average value of F_G obtained for each 560 TRY based on all of the SURFRAD stations.

$$F_G = F_1 + (F_2 + F_3 + F_4)/3 + (F_5 + F_6)/2 + (F_7 + F_8)/2$$
(20)

The results show that TRY_{WYSSd} performs well, achieving the lowest overall score for all of the stations. It is followed by TRY_{TGYd} , TRY_{WYSSm} , and TRY_{FRPd} which rank second, third and forth with very close global scores. However, when the overall results analysis is restricted to the reference years obtained from the analysis of meteorological variables, it can be seen how TRY_{TGYd} performs best, followed by TRY_{TDYd} and 566 TRY_{TMY3d}. Precisely the methodology for obtaining both TGY and TDY is based on a

	Station code											
TRY	BON	DRA	FPK	GWN	PSU	SXF	TBL	- Total				
WYSSd	9.00	11.00	4.33	8.00	6.00	7.00	6.00	7.33				
TGYd	16.00	28.00	22.67	17.00	20.00	20.67	27.00	21.62				
WYSSm	20.00	23.00	28.67	18.00	24.00	19.00	23.00	22.24				
FRPd	26.00	25.67	17.33	21.00	25.00	33.00	16.00	23.43				
TDYd	31.00	28.17	25.00	26.67	22.67	20.67	28.00	26.02				
TMY3d	27.50	26.00	30.00	27.00	27.00	22.67	28.00	26.88				
TGYm	33.00	27.50	28.50	29.00	33.00	34.00	37.00	31.71				
TDYm	30.00	29.50	33.67	35.17	27.33	34.67	32.00	31.76				
ISOm	32.00	27.00	24.17	31.83	43.83	30.17	34.00	31.86				
FRMd	33.00	31.00	33.00	35.33	23.50	37.00	36.00	32.69				
TMY3m	25.00	31.33	40.67	31.00	38.67	33.67	32.00	33.19				
ISOd	37.50	35.50	39.00	37.33	38.50	36.00	37.00	37.26				
FRMm	52.00	44.33	41.00	47.67	51.50	38.50	37.00	44.57				
FRPm	48.00	52.00	52.00	55.00	39.00	53.00	47.00	49.43				

567 single variable (global horizontal irradiance and direct normal irradiance respectively).

Table 13. Values of F_G (overall performance of each TRY) obtained by the TRYs for each station and total score.

568 It should be noted that under the overall classification, the modified version of the 569 TRYs proposed in this work performs better than their original monthly-based versions. Conversely, the TRY generated following the EN ISO 15927-4 original procedure 570 571 obtained better results than that generated from the proposed adjustment for the selection 572 of typical days. This was found for six of the seven stations.

573 In all instances, the highest F_G values were obtained from the two TRYs generated 574 according to the original Festa-Ratto method, i.e., by concatenating twelve typical real 575 months. Paradoxically, for all of the stations except for Penn. State (PSU), the Festa-Ratto 576 reference year obtained from the production variable achieves worse scores than that 577 generated from meteorological variables.

578 For a better appreciation of the results, Fig. 7 illustrates overall F_G values obtained 579 when considering all of the stations. F_G values of the various TRYs were ordered from 580 lowest to highest. Thus, the lower the value of F_G , the better the global performance becomes. Bars for daily reference years are shown in dark gray, while light gray barscorrespond to TRYs composed of typical months.

583 5. CONCLUSIONS

In this paper, the effects of the temporal downscaling of typical periods that integrate three different TRYs on performance in the evaluation of the long-term behavior of PV systems have been analyzed. The following modified versions of six methods for the generation of TRYs have been proposed for selecting typical days rather than typical months: the Festa-Ratto TRY, WYSS, ISO TRY, TMY3, TDY and TGY. Consequently, these new TRYs are composed of a concatenation of 365 typical days.

The behavior of the TRYs obtained through the modified procedures has been compared to that constructed following the original procedure based on meteorological data recorded from the seven SURFRAD stations (USA). While the ISO, TMY3, TDY and TGY methods are based on the analysis of series of meteorological data, the procedure for obtaining the WYSS employs solar system production. The Festa-Ratto procedure, however, allows for the use of both meteorological and production variables. Thus, for each location, 7 daily TRYs and 7 monthly TRYs have been generated.

597 The results obtained from this work confirm that the timescale reduction proposed 598 significantly improve for most locations the overall behavior of TRY_{FR}, TRY_{WYSS}, 599 TRY_{TMY3}, TRY_{TGY} and TRY_{TDY} when estimating the electricity production of a PV 600 system over the long term considering the hourly, daily, monthly and annual situations. 601 In the particular case of TRY_{FR}, improvements are detected regardless of whether 602 meteorological or system production values are used. However, the modification of the 603 ISO method for the selection of typical days leads to a worsening of global results with 604 respect to the monthly version of the procedure.

When analyzing the results obtained in different time scales it is observed that, in an annual and monthly scenario, TRYs composed of typical months outperform those obtained by the modifications proposed in this work for the selection of typical days, except in the case of the Festa-Ratto method. Conversely, the daily versions of the different reference years present a better behavior than the monthly TRYs on a daily and hourly scale. Therefore, it is not possible to state categorically that in all cases a temporal downscaling of typical moments translates into an improvement of TRY performance.

612 The results presented in Table 5 to Table 12 provide users with some guidance in 613 selecting the most appropriate TRY for estimating the long-term performance of a PV 614 system, according to their needs and motivations. It was found that the TRY_{WYSSd}, a 615 production-based reference year, achieved the best overall performance when all time 616 scales were considered. However, if a user wishes to avoid the use of a multi-year 617 simulation, then the TRY_{TGYd} method, the daily version of the TGY method proposed by 618 NREL, would be recommended to evaluate the long-term performance of a PV system 619 for all timescales.

Finally, one aspect that was not addressed in this study was the issue of solar tracking. This study focused solely on the choice of a TRY for a fixed tilt PV system. One might hypothesize that a different choice of TRY might occur when estimating the long-term performance of tracking-based systems. In particular, one might expect that a TDY may outperform a TGY for tracking based systems, given the higher dependence on direct normal irradiance for tracking based systems in comparison to fixed tilt systems. This issue should be explored in future work.

627 ACKNOWLEDGMENTS

628 The authors would like to thank the Surface Radiation Budget Network for providing629 fundamental data for this work and the anonymous reviewers for their useful comments

630 that greatly improved this paper. They also thank the Public University of Navarre for 631

632 REFERENCES

- 633 [1] National Climatic Data Center, Test reference year (TRY), in: Tape Ref. Manual,
- 634 TD-9706, Asheville, NC, USA, 1976.

awarding Ignacio García Ruiz a Doctoral Fellowship.

- 635 [2] T. Lhendup, S. Lhundup, Comparison of methodologies for generating a typical 636 meteorological year (TMY), Energy Sustain. Dev. 11 (2007) 5-10.
- 637 doi:10.1016/S0973-0826(08)60571-2.
- 638 [3] I.J. Hall, R.R. Prairie, H.E. Anderson, E.C. Boes, Generation of Typical
- 639 Meteorological Years for 26 SOL-MET stations, in: Rep. SAND 78-1601, Sandia 640 National Laboratories, Albuquerque, NM, USA, 1978.
- 641 [4] J.M. Finkelstein, R.E. Schafer, Improved goodness-of-fit tests, Biometrika. 58 642 (1971) 641-645. doi:10.1093/biomet/58.3.641.
- D. Pissimanis, G. Karras, V. Notaridou, K. Gavra, The generation of a "typical 643 [5]
- 644 meteorological year" for the city of Athens, Sol. Energy. 40 (1988) 405-411.
- 645 doi:10.1016/0038-092X(88)90095-3.
- 646 M. Petrakis, H.D. Kambezidis, S. Lykoudis, A.D. Adamopoulos, P. Kassomenos, [6]
- 647 I.M. Michaelides, S.A. Kalogirou, G. Roditis, I. Chrysis, A. Hadjigianni,
- 648 Generation of a "typical meteorological year" for Nicosia, Cyprus, Renew.
- 649 Energy. 13 (1998) 381-388. doi:10.1016/S0960-1481(98)00014-7.
- 650 N.M. Sawaqed, Y.H. Zurigat, H. Al-Hinai, A step-by-step application of Sandia [7]
- 651 method in developing typical meteorological years for different locations in
- 652 Oman, Int. J. Energy Res. 29 (2005) 723-737. doi:10.1002/er.1078.
- 653 [8] O.S. Ohunakin, M.S. Adaramola, O.M. Oyewola, R.L. Fagbenle, F.I. Abam, A
- 654 typical meteorological year generation based on nasa satellite imagery (GEOS-I)

- 655 for sokoto, Nigeria, Int. J. Photoenergy. 2014 (2014). doi:10.1155/2014/468562.
- 656 [9] W. Marion, K. Urban, User's Manual for TMY2s: Typical Meteorological Years:
- 657 Derived from the 1961-1990 National Solar Radiation Data Base, in: Tech. Rep.
- 658 TP-463-7668, National Renewable Energy Laboratory, Golden, CO, USA, 1995.
- 659 [10] S.A. Kalogirou, Generation of typical meteorological year (TMY-2) for Nicosia,
- 660 Cyprus, Renew. Energy. 28 (2003) 2317–2334. doi:10.1016/S0960-
- 661 1481(03)00131-9.
- 662 [11] T.T. Chow, A.L.S. Chan, K.F. Fong, Z. Lin, Some perceptions on typical weather
- year-from the observations of Hong Kong and Macau, Sol. Energy. 80 (2006)
 459–467. doi:10.1016/j.solener.2005.04.017.
- 665 [12] H. Zang, Q. Xu, P. Du, K. Ichiyanagi, A Modified Method to Generate Typical
 666 Meteorological Years from the Long-Term Weather Database, Int. J.

667 Photoenergy. 2012 (2012) 2–9. doi:10.1155/2012/538279.

- [13] D.J. Thevenard, A.P. Brunger, The Development of Typical Weather Years for
 International Locations: Part I, Algorithms, ASHRAE Trans. 108 (2002) 376–
 383.
- 671 [14] A.L.S. Chan, T.T. Chow, S.K.F. Fong, J.Z. Lin, Generation of a typical
- 672 meteorological year for Hong Kong, Energy Convers. Manag. 47 (2006) 87–96.
 673 doi:10.1016/j.enconman.2005.02.010.
- 674 [15] A.L.S. Chan, Generation of typical meteorological years using genetic algorithm
 675 for different energy systems, Renew. Energy. 90 (2016) 1–13.
- 676 doi:10.1016/j.renene.2015.12.052.
- 677 [16] S. Pusat, İ. Ekmekçi, M.T. Akkoyunlu, Generation of typical meteorological year
 678 for different climates of Turkey, Renew. Energy. 75 (2015) 144–151.
- 679 doi:10.1016/j.renene.2014.09.039.

- 680 [17] F. Bre, V.D. Fachinotti, Generation of typical meteorological years for the
 681 Argentine Littoral Region, Energy Build. 129 (2016) 432–444.
- 682 doi:10.1016/j.enbuild.2016.08.006.
- 683 [18] S. Wilcox, W. Marion, Users Manual for TMY3 Data Sets, in: Tech. Rep. TP-
- 581-43156, National Renewable Energy Laboratory, Golden, CO, USA, 2008.
- 685 [19] European Committee for Standardization, EN ISO 15927-4:2005 Hygrothermal
- 686 performance of buildings Calculation and presentation of climatic data. Part 4:
 687 Hourly data for assessing the annual energy use for heating and cooling, 2005.
- 688 [20] J. Kragh, F. Pedersen, S. Svendsen, Weather test reference years of Greenland,
- 689 in: Proc. Nord. Symp. Build. Phys., Reykjavik, 2005.
- 690 [21] T. Kalamees, J. Kurnitski, Estonian test reference year for energy calculations,

691 in: Proc. Est. Acad. Sci. Eng., Tallinn, Estonia, 2006: pp. 40–58.

- 692 [22] K. Lee, H. Yoo, G.J. Levermore, Generation of typical weather data using the
- ISO Test Reference Year (TRY) method for major cities of South Korea, Build.
 Environ. 45 (2010) 956–963. doi:10.1016/j.buildenv.2009.10.002.
- 695 [23] M. Ruduks, A. Lešinskis, Generation of a Test Reference Year for Alūksne,
- 696 Latvia, Proc. Latv. Univ. Agric. 33 (2015) 46–54. doi:10.1515/plua-2015-0006.
- 697 [24] T. Kalamees, K. Jylhä, H. Tietäväinen, J. Jokisalo, S. Ilomets, R. Hyvönen, S.
- 698 Saku, Development of weighting factors for climate variables for selecting the
- 699 energy reference year according to the EN ISO 15927-4 standard, Energy Build.
- 700 47 (2012) 53–60. doi:10.1016/j.enbuild.2011.11.031.
- 701 [25] G. Pernigotto, A. Prada, D. Cóstola, A. Gasparella, J.L.M. Hensen, Multi-year
 702 and reference year weather data for building energy labelling in north Italy
- 703 climates, Energy Build. 72 (2014) 62–72. doi:10.1016/j.enbuild.2013.12.012.
- 704 [26] G. Pernigotto, A. Prada, A. Gasparella, J.L.M. Hensen, Analysis and

- 705 improvement of the representativeness of EN ISO 15927-4 reference years for
- building energy simulation, J. Build. Perform. Simul. 7 (2014) 391–410.
- 707 doi:10.1080/19401493.2013.853840.
- M. Eames, A. Ramallo-Gonzalez, M. Wood, An update of the UKs test reference
 year: The implications of a revised climate on building design, Build. Serv. Eng.
- 710 Res. Technol. 37 (2015) 316–333. doi:10.1177/0143624415605626.
- [28] G.J. Levermore, J.B. Parkinson, Analyses and algorithms for new Test Reference
 Years and Design Summer Years for the UK, Build. Serv. Eng. Res. Technol. 27
 (2006) 311–325. doi:10.1177/0143624406071037.
- [29] I. García, J.L. Torres, Assessment of the adequacy of EN ISO 15927-4 reference
 years for photovoltaic systems, Prog. Photovoltaics Res. Appl. 23 (2015) 1956–
 1969. doi:10.1002/pip.2617.
- 717 [30] M. Gazela, E. Mathioulakis, A new method for typical weather data selection to
 718 evaluate long-term performance of solar energy systems, Sol. Energy. 70 (2001)
 719 339–348. doi:10.1016/S0038-092X(00)00151-1.
- 720 [31] A. Habte, A. Lopez, M. Sengupta, S. Wilcox, Temporal and Spatial Comparison
- 721 of Gridded TMY, TDY, and TGY Data Sets, in: Tech. Rep. TP-5D00-60886,
- 722 National Renewable Energy Laboratory, Golden, CO, USA, 2014.
- 723 [32] A. Argiriou, S. Lykoudis, S. Kontoyiannidis, C.A. Balaras, D. Asimakopoulos,
- 724 M. Petrakis, P. Kassomenos, Comparison of methodologies for TMY generation
- vising 20 years data for Athens, Greece, Sol. Energy. 66 (1999) 33–45.
- 726 doi:10.1016/S0038-092X(99)00012-2.
- 727 [33] B. Andersen, S. Eidorff, H. Lund, E. Pedersen, S. Rosenørn, O. Valbjørn,
- 728 Meteorological Data for Design of Building and Installation: A Reference Year
- 729 (extract), in: Rep. No 66, 2nd Ed, Thermal Insulation Laboratory, Denmark,

730 1977.

- [34] H. Lund, S. Eidorff, Selection methods for production of test reference years, in:
 Final Rep. EUR 7306 EN, Commission of the European Communities,
- T33 Luxembourg, 1981.
- 734 [35] R. Festa, C.F. Ratto, Proposal of a numerical procedure to select Reference
- 735 Years, Sol. Energy. 50 (1993) 9–17. doi:10.1016/0038-092X(93)90003-7.
- 736 [36] P. Sprent, Applied nonparametric statistical methods, 2nd ed., Chapman&Hall,
 737 London, 1993.
- 738 [37] J. Bilbao, A. Miguel, J.A. Franco, A. Ayuso, Test Reference Year Generation and
- 739 Evaluation Methods in the Continental Mediterranean Area, J. Appl. Meteorol.
- 740 43 (2004) 390–400. doi:10.1175/1520-
- 741 0450(2004)043<0390:TRYGAE>2.0.CO;2.
- 742 [38] D. Feuermann, J.M. Gordon, Y. Zarmi, A typical meteorological day (TMD)
- approach for predicting the long-term performance of solar energy systems, Sol.

744 Energy. 35 (1985) 63–69. doi:10.1016/0038-092X(85)90037-4.

- 745 [39] C.N. Long, E.G. Dutton, BSRN Global Network Recommended QC Tests, v2.0,
- in: Rep. No 1-3, Baseline Surface Radiation Network, 2002.
- 747 [40] D.T. Reindl, W.A. Beckman, J.A. Duffie, Diffuse fraction correlations, Sol.
- 748 Energy. (1990). doi:10.1016/0038-092X(90)90060-P.
- 749 [41] J.E. Hay, J.A. Davies, Calculation of the solar radiation incident on an inclined
- 750 surface, in: Proc. First Can. Sol. Radiat. Data Work., Ministry of Supply and
- 751 Services, Toronto, Canada, 1980: pp. 59–72.